



STREAM NO.	5001	5002	5003	5004	5005	5006	5007 (NOTE 7)
TEMPERATURE, °C	47	25	37	37	37	37	37
PRESSURE, Barg	3.5	5.5	5.5	0.31	5.5	5.5	2
TOTAL MASS FLOW, kg/h	24960575	532430	24960575	26283485	74882	1248029	520
DENSITY, kg/m3	990.7	1007.5	998.4	998.3	998.4	998.4	998.3
VISCOSITY, Cp	0.57	0.89	0.69	0.69	0.69	0.69	0.69

REFERENCE DRAWINGS

DWG. NUMBER

Note :

1. DELETED.
2. DELETED.
3. DELETED.
4. DELETED.
5. 7 ELECTRICAL PUMPS ARE CONSIDERED FOR COOLING WATER PUMPS. (5 DUTY PUMPS + 2 SPARE PUMPS).
6. REQUIRED CONTROL FLOW VALVE SHALL BE CONSIDERED BY FILTRATION PACKAGE VENDOR.
7. STREAM PRESSURE AND BACK WASH FLOW RATE ARE PRELIMINARY AND WILL BE FINALIZED BY VENDOR DURING DETAIL DESIGN.
8. DELETED.
9. DELETED.
10. 6 (5+1) COOLING WATER CELLS CONSIDERED.
11. DELETED.
12. DELETED.
13. DELETED.
14. DELETED.
15. THE LOCATION OF PACKAGE 83-W-901 WILL BE CHECKED AND FINALIZED DURING DETAILED DESIGN ENGINEERING PHASE AS PER CONTRACT.

Legend :

01	ISSUED FOR APPROVAL	22-Sep-2025	M.HASSANI	M.JAMSHIDI	M.H.ESHRAGHI
00	ISSUED FOR COMMENT	18-Dec-2024	M.FALLAHI	M.JAMSHIDI	E.SHAFAGHATI
REV.	PURPOSE OF ISSUE	ISSUE DATE	PREPARE	CHECKED	APPROVED
OWNER:			MC:		
PROJECT TITLE:			CONTRACTOR/CONSULTANT:		
PROPANE DEHYDROGENATION (PDH) PROJECT					
DOCUMENT TITLE:					
PFD for Cooling Tower System					
DOC NO.:	PROJ.CODE	Sec.	PHASE	DEP.	DOC. TYPE
	3981	50	DE	PR	PFD
SCALE: 1:100	SIZE: A3	SHEET NO: 1 OF 1		REVISION: 01	CLASS: 1

This document contains confidential proprietary information belonging to Parsian Petrochemical Co. and should not be disclosed to any third party without the prior written consent of Parsian Petrochemical Co.